

Date: 04-09-2023

It is certified that an inspection team headed by Er. Shivam Mishra, Executive Engineer  
(Name of Officers with designation) from Jalkal Vibhag, Nagar Nigam Prayagraj  
(Name of Department/ Office) inspected the Tagore Public School Attarsuiya Prayagraj.

(Name & Address of the school) on 02-09-2023 (date of inspection) and found that the  
Tagore Public School (Name of school) has safe drinking water  
facilities for the students and members of staff of the institution and is maintaining the hygienic  
sanitation condition in the school building & the campus as per norms prescribed by the Central/  
State/ U.T. Govt.

The above is valid for a period of three months only.

Signature with Seal

अधिरासी अभियन्ता (मु०)

जलकल विभाग, नगर निगम

Name

Er. Shivam Mishra

Designation

Executive Engineer

Name & Address of the Office / Department

To

Principal  
Tagore Public School  
Attarsuiya Prayagraj  
(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Archana Tewari  
Principal  
Tagore Public School  
Attarsuiya, Allahabad

Manager  
Tagore Public School  
179-A, Attarsuiya  
Allahabad - 211003

PRAYAGRAJ JAL KAL VIBHAG LABORATORY  
CHEMICAL ANALYSIS OF WATER

Test Report

Sl. NO

1. Source of sample *Water sample, Tagore public school, campus, 179, Attarsuiya Allahabad*  
2. Date of Sampling *21/9/2023 Received.*  
3. Date of Analysis *21/9/2023*

Physico Chemical Parameter	BIS Limits IS 10500 : 2012		Result of test
	Requirement (Desirable Limit) Mg/l	Permissible limit In the absence of Alternate source Mg/l	
4. Total Dissolved solids	500	2000	350
5. Hardness Total as CaCO <sub>3</sub>	200	600	166
6. Hardness Temporary as CaCO <sub>3</sub>	NS	NS	83
7. Hardness Permanent as CaCO <sub>3</sub>	NS	NS	83
8. Chlorine as Chlorides Cl	250	1000	90
9. Total Alkalinity as CaCO <sub>3</sub>	200	600	45
10. Nitrites as NO <sub>2</sub>	NS	NS	Nil
11. Iron as Fe	0.3	No relaxation	0.1
12. Fluoride as F	1.0	1.5	0.6
13. Colour Hazen Unit	5	15	Colourless
14. Taste	Agreeable	Agreeable	Not tasted
15. Odour	Agreeable	Agreeable	Odourless
16. pH Value	6.5 to 8.5	No relaxation	7.4
17. Conductivity as $\mu$ msh at 20°C	NS	NS	500
18. Turbidity NTU	1	5	0.8
19. Free Residual Chlorine	0.2	NS	Nil

*Potable*

Remarks

*[Signature]*  
Chemist

*[Signature]*

अधिसारी अभियन्ता (मुख्यालय)  
जलकल विभाग, नगर निगम  
प्रयागराज

Copy forwarded for information to

- The addl. Director, State Health Institute, Sector-C, Chetan Bihar, Aliganj, Lucknow, U.P.
- Chief Medical Officer, Prayagraj.
- Mukhya Nagar Swasthya Adhikari, Nagar Nigam. Prayagraj.
- Nagar Ayukta, Nigar Nigam, Prayagraj.
- The Suprintending Engineer (R&D) office of Addl. Chief Engineer (PPR&D), U.P. Jal Nigam, 6 Rana Pratap marg, Lucknow.
- Chairman, jalkal Vibhag/Mayor, Nigam, Prayagraj.

*[Signature]*  
Archana Tewari  
Principal  
Tagore Public School

*[Signature]* E.E.  
Manager  
Tagore Public School  
179-A, Attarsuiya  
Allahabad - 211003

# ALLAHABAD JAL KAL VIBHAG LABORATORY

Result of the Bacteriological examination of the Water taken from Water Sample

Name & Designation of the person collecting the sample Archana Tewari & Principal

Date & time of collection	Date of receipt and inoculation	Source of Sample	Colony Count on agar plate in 1 ml.		Presumptive coliform count			Probable No. of coliform organism in 100 ml. of original water	Free residual chlorine mg/l	Remarks
			At 37°C in 48 hours	At room temperature in 72 hours	Quantity of water put up in each tube/No. of tubes put up	50 ml.	10 ml.			
9/2/23	2/9/2023	Water Sample Tagore public school 179-A, Attarsuiya Allahabad. (Prayagraj)	-	-	1	5	0	0	Nil	Excellent

*Archana Tewari*  
Principal  
Tagore Public School  
Attarsuiya, Allahabad

*Manager*  
Tagore Public School  
179-A, Attarsuiya  
Allahabad - 211003

*[Signature]*  
Chemist

Chief Chemist

Ex. Engineer (HQ)  
अधिरासी अभियन्ता (HQ)  
जलकल विभाग, नगर निगम  
प्रयागराज